WEST CAPE MAY BOARD OF EDUCATION

301 Moore Street
West Cape May, New Jersey 08204-1199
(609) 884-4614/ FAX (609) 884-0932

Alfred Savio, Ed.D.
Chief School Administrator
School Business Administrator/Board Secretary

Maureen McLaughlin
Supervisor

March 9, 2017

Dear Parents/Guardians:

I am pleased to report that pursuant to N.J.A.C. 6A:26-1.2 and 12.4 the district completed lead testing of water outlets throughout the building last month. The results are included. As you can see the certified testing lab measured less than 2 parts per billion of lead in the drinking water, while the standard is less than 15 parts per billion before remediation is required.

Should you have any questions or concerns regarding this matter, feel free to contact the district during normal school hours to discuss your concerns with me. Thank you for your continued support of our school.

Sincerely,

Dr. Alfred Savio, Chief School Administrator

	A	B	C	D	E	F	G	H	I	J	K	L	M	N	O
1	Field ID	Flushed Y/N	Laboratory sample ID	Laboratory Name	Lab Certification ID	Date Sampled	Time Sampled	Analytical Method	Date of Analysis	Time of Analysis	Concentration in ug/L	Reporting Limit (ug/L)	Dilution Factor	Digested (Y/N)	Qualifier
2	TB021617TDPb	N	51081-1	CEL	05679	2/15/2017	5:00p	SM3113B	2/21/2017	10:00a	<2.00	2.00	1	N	
3	WCM-TL-1	N	51081-2	CEL	05679	2/16/2017	7:23am	SM3113B	2/21/2017	10:00a	<2.00	2.00	1	N	
4	WCM-DW-2L	N	51081-3	CEL	05679	2/16/2017	7:24am	SM3113B	2/21/2017	10:00a	<2.00	2.00	1	N	
5	WCM-DW-1R	N	51081-4	CEL	05679	2/16/2017	7:25am	SM3113B	2/21/2017	10:00a	<2.00	2.00	1	N	
6	WCM-WC-1	N	51081-5	CEL	05679	2/16/2017	7:26am	SM3113B	2/21/2017	10:00a	<2.00	2.00	1	N	
7	WCM-DW-2L	N	51081-6	CEL	05679	2/16/2017	7:27am	SM3113B	2/21/2017	10:00a	<2.00	2.00	1	N	
8	WCM-DW-2R	N	51081-7	CEL	05679	2/16/2017	7:27am	SM3113B	2/21/2017	10:00a	<2.00	2.00	1	N	
9	WCM-WC-2L	N	51081-8	CEL	05679	2/16/2017	7:29am	SM3113B	2/21/2017	10:00a	<2.00	2.00	1	N	
10	WCM-WC-2R	N	51081-9	CEL	05679	2/16/2017	7:29am	SM3113B	2/21/2017	10:00a	<2.00	2.00	1	N	
11	WCM-FP	N	51081-10	CEL	05679	2/16/2017	7:31am	SM3113B	2/21/2017	10:00am	<2.00	2.00	1	N	
12	TB022817TDPb	N	TB022817TDPb	CEL	05679	2/27/2017	5:00pm	SM3113B	3/1/2017	11:50am	<2.00	2.00	1	N	
13	WCM-DW-3	N	51171	CEL	05679	2/28/2017	7:39am	SM3113B	3/1/2017	11:50am	<2.00	2.00	1	N	
14															
15															